

CP2108 City Hall HVAC Replacement – Pre-proposal Meeting Q&A

Is Commissioning required? If so, is the contractor required to hire a Commissioning Agent?

A commissioning agent will be required and hired by the contractor.

Is there any preference on equipment manufactures?

No preference, but documentation will need to be provided showing that the installed equipment is more efficient than the current.

What are the work hours?

Assuming the building will be occupied, are there any restrictions related to system shutdowns?

Most if not all work can be done during regular work hours (some scheduling around meetings might be necessary). Most employees in the building are currently working from home.